



# RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-DYGC-UP\_DYGL-UP

Date: 3 July 2021

We:	Clevertronics Pty Ltd	Clevertronics Pty Ltd
	1 Caribbean Drive	Unit 22/761 Great South Road
	Scoresby VIC 3179 Australia	Penrose, Auckland 1061, New Zealand
	T: +61 3 9559 2700	T: +64 800 548 448
	E: <a href="mailto:Productenquiry@clevertronics.com.au">Productenquiry@clevertronics.com.au</a>	E: <a href="mailto:Productenquiry@clevertronics.com.au">Productenquiry@clevertronics.com.au</a>
ABN: 64 136 264 349	NZBN: 9429042377382	

declare that the DYRC-UP-R-HV and following associated product codes

DYGC-UP-ww-xx-yy-zz	LP Dynamic Green UltraBlade Pro
DYGL-UP-ww-xx-yy-zz	L10 Dynamic Green UltraBlade Pro
DYGC-UP-ww-TH-xx-yy	LP Dynamic Green UltraBlade Pro, Theatre Mask
DYGL-UP-ww-TH-xx-yy	L10 Dynamic Green UltraBlade Pro, Theatre Mask

Where,

ww = Blank	Recessed Mounted
ww = WM	Wall Mounted
ww = CM	Ceiling Mounted
xx = R	Running Man Decal
xx = RL	Left-Arrow Running-Man-Left Decal
xx = RR	Running-Man-Right Right-Arrow Decal
xx = DS-R	Double sided Running Man Decal
xx = DS-RAOW	Double sided Running Man Arrow One Way Decal
yy = Blank	Manual Test/Clevertest Plus (CTP)
yy = ZW	Zoneworks
yy = HV	Zoneworks XT HIVE
yy = DATA	Zoneworks DATA
yy = DALI	DALI Registered
zz = Blank	Default colour code - White
zz = "Custom colour code"	Custom defined colour code
zz = BLK	Housing Colour- BLACK
zz = GRY	Housing Colour- Grey
zz = SLV	Housing Colour- Silver
zz = WHT	Housing Colour- White

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992

Responsible Supplier Number E7500  
Clevertronics is registered with ERAC EESS and ACMA



## RCM DECLARATION OF CONFORMITY

- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings Emergency luminaires and exit signs

AS 60598.2.22:2019

Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

**Tony Todaro**  
Managing Director

