



# RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-ODYSSEYQUANTUMWG

Date: 18 November 2022

We: Clevertronics Pty Ltd  
1 Caribbean Drive  
Scoresby VIC 3179 Australia  
T: +61 3 9559 2700  
E: [Productenquiry@clevertronics.com.au](mailto:Productenquiry@clevertronics.com.au)  
ABN: 64 136 264 349

Clevertronics Pty Ltd  
Unit 22/761 Great South Road  
Penrose, Auckland 1061, New Zealand  
T: +64 800 548 448  
E: [Productenquiry@clevertronics.com.au](mailto:Productenquiry@clevertronics.com.au)  
NZBN: 9429042377382

declare that the **CBS2L4S-LT-WG-MS-HV** and the following associated product codes

- |                     |                 |
|---------------------|-----------------|
| CBS1L2S-LT-WG-aa-bb | FBS1L2-LT-WG-aa |
| CBS1L4S-LT-WG-aa-bb | FBS1L4-LT-WG-aa |
| CBS2L2S-LT-WG-aa-bb | FBS2L2-LT-WG-aa |
| CBS2L4S-LT-WG-aa-bb | FBS2L4-LT-WG-aa |
| EBS1L2S-WG-aa-LI    | FBS1L2-WG-aa    |
| EBS1L4S-WG-aa-LI    | FBS1L4-WG-aa    |
| EBS2L2S-WG-aa-LI    | FBS2L2-WG-aa    |
| EBS2L4S-WG-aa-LI    | FBS2L4-WG-aa    |

Where,

Wildcard	Description	Wildcards	Description
aa = Blank	Non-MS version	bb = HV	Zoneworks XT HIVE (915MHz)
aa = MS	MS version	bb = HVG	Zoneworks XT HIVE (2.4GHz)
bb = Blank	Manual Test/Clevertest Plus (CTP)	bb = DATA	Zoneworks DATA
bb = ZW	Zoneworks XT	bb = DALI	DALI Registered

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet requirements of the following standards:

- |                                 |  |
|---------------------------------|--|
| AS/NZS 2293.3:2018              | Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs  |
| AS 60598.2.22:2019              | Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)                                       |
| AS/NZS 60598.2.1:2014 + A2:2019 | Luminaires Particular requirements - Fixed general-purpose Luminaires  |
| AS CISPR 15:2017                | Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013 + AMD1:2015 (ED.8.1) MOD) |

**Michael Duce**  
National Systems and Engineering Manager

