



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-WPLIFELIGHTPRO
Date: 26 October 2021
We: Clevertronics Pty Ltd
1 Caribbean Drive
Scoresby VIC 3179 Australia
T: +61 3 9559 2700
E: Productenquiry@clevertronics.com.au
ABN: 64 136 264 349

Clevertronics Pty Ltd
Unit 22/761 Great South Road
Penrose, Auckland 1061, New Zealand
T: +64 800 548 448
E: Productenquiry@clevertronics.com.au
NZBN: 9429042377382

declare that the CWPLIFE-PRO-HV and following associated product codes

aWPLIFEb-PRO-cc-dd-ee-ff-gg
aWP2LIFEb-PRO-cc-dd-ee-ff-gg

Where,

| | |
|---------------------------|--|
| a = L | L10 Battery |
| a = C | LP Battery |
| b = Blank | Non-Maintained fitting |
| b = M | Maintained fitting |
| cc = Blank | LEDs housed internal to weatherproof enclosure |
| cc = WPP0D | LEDs housed in external weatherproof Pod |
| dd = Blank | Standard non-freezer fitting |
| dd = FZR | Freezer fitting with double batteries |
| ee = Blank | Manual Test/Clevertest Plus (CTP) |
| ee = ZW | Zoneworks |
| ee = HV | Zoneworks XT HIVE |
| ee = DATA | Zoneworks DATA |
| ee = DALI | DALI Registered |
| ff = Blank | Surface Mount |
| ff = CM | Ceiling Mount |
| ff = WM | Wall Mount |
| gg = Blank | Standard Housing Colour |
| gg = BLK | Custom Black Housing Colour |
| gg = WHT | Custom White Housing Colour |
| gg = DGRY | Custom Dark Gray Housing Colour |
| gg = MSLV | Custom Matt Silver Housing Colour |
| gg = "Custom colour code" | Custom defined housing colour code |



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC)

these products meet the following standards:

| | |
|--------------------|--|
| AS/NZS 2293.3:2018 | Emergency lighting and exit signs for buildings - Emergency luminaires and exit signs |
| AS 60598.2.22:2019 | Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD) |
| AS CISPR 15:2017 | Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD) |

Michael Duce
National Systems and
Engineering Manager

