



RCM DECLARATION OF CONFORMITY

Document No: CLEV-RCM-CLEVERFIT

Date: 27 September 2021

We:

| | |
|--|---|
| Clevertronics Pty Ltd 1 Caribbean Drive Scoresby VIC 3179 Australia T: +61 3 9559 2700 E: Productenquiry@clevertronics.com.au ABN: 64 136 264 349 | Clevertronics Pty Ltd Unit 22/761 Great South Road Penrose, Auckland 1061, New Zealand T: +64 800 548 448 E: Productenquiry@clevertronics.com.au NZBN: 9429042377382 |
|--|---|

declare that the CCFLED-HV and following associated product codes

CCFLED-aa-bb-cc-dd-ee
LCFLED-aa-bb-cc-dd-ee

Where,

| | |
|---------------------------|--|
| aa = Blank | Standard fitting |
| aa = TH | Theatre fitting |
| bb = Blank | Manual Test/Clevertest Plus (CTP) |
| bb = ZW | Zoneworks |
| bb = HV | Zoneworks XT HIVE |
| bb = DATA | Zoneworks DATA |
| bb = DALI | DALI Registered |
| cc = Blank | Standard fitting |
| cc = 4HR | 4-hour emergency run-time fitting |
| cc = UPS | Changeover Central Supplied from a UPS (240V AC) |
| dd = Blank | One-box Solution |
| dd = E | EXIT Decal |
| dd = R | Running Man Decal |
| dd = RL | Running Man Left Arrow Decal |
| dd = RR | Running Man Right Arrow Decal |
| dd = DS-E | Double sided EXIT Decal |
| dd = DS-R | Double sided Running Man Decal |
| dd = DS-RAOW | Double sided Running Man Arrow One Way Decal |
| dd = SP | Special Purpose sign |
| ee = Blank | Housing Colour - Standard colour |
| ee = BLK | Housing Colour - Black |
| ee = DULSN4H4 | Housing Colour - Dulux Stepney |
| ee = "Custom colour code" | Housing Colour - custom define colour code |



RCM DECLARATION OF CONFORMITY

are in conformity with the requirements of the:

- AS/NZS 4417.1:2012 & AS/NZS 4417.2:2018 in-scope electrical equipment and AS/NZS 3820:2009 (Essential safety requirements for electrical equipment)
- Radiocommunications Labelling (Electromagnetic Compatibility) Notice 2017 made under section 182 of the Radiocommunications Act 1992
- Australian Communications and Media Authority (ACMA) for Electromagnetic Compatibility (EMC).

Above products meet the following standards:

AS/NZS 2293.3:2018

Emergency lighting and exit signs for buildings Emergency luminaires and exit signs

AS 60598.2.22:2019

Luminaires – Part 2.22: Particular requirements – Luminaires for emergency lighting (IEC 60598-2-22:2017 (ED.4.1) MOD)

AS CISPR 15:2017

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment (CISPR 15:2013+AMD1:2015 (ED.8.1) MOD)

Michael Duce

National Systems and Engineering
Manager

