



LLIFE-SM-WP-CL

CLEVERTRONICS L10 LIFELIGHT IP65 WEATHERPROOF
SURFACE MOUNTED EMERGENCY LUMINAIRE WITH CORRIDOR LENS



PRODUCT INFORMATION	
Part Number	LLIFE-SM-WP-CL
MIC	AUD01320050001
Description	L10 Optimum Lifelight, Weatherproof, Surface Mounted Emergency Light with Corridor Lens, Enabled with Clevertest Plus
Construction	Polycarbonate Enclosure
Mounting	Surface Mounted
Dimensions L x W x H	247mm x 129mm x 51mm
Weight	0.8kg
Operating Mode	Non-maintained
Testing System	Clevertest Plus Enabled (Not activated by default)
Battery	Lithium Nanophosphate, 3.3V 2500mAh
Charging Method	Intelligent Current Limited Constant Voltage
Lamp(s)	1 x High intensity LED
Operating Voltage	240V AC; 50Hz
Power Consumption	1W (Standby) 4.2W (Max)
IP Rating	IP65
IK Rating	IK08
Operating Temperature	0°C to 40°C
AS2293 Classification	N/A – Refer to Manufacturers' Recommended Spacing Table on the next page
Applicable Standards	AS/NZS3820, CISPR15, AS/NZS2293.3
Compliance Marking (RCM)	

REPLACEMENT PARTS	
PART NUMBER	DESCRIPTION
1530071	BATTERY:L10 3.3V 2.5AH 200mm ld, no Brkt
8050174	LED: PCA: HWSUB: CT10694-D1
8002938	Driver: PCA: LLIFE CT10260-L5 1C550 CTP AU Vert Connectors

The product details described in this document are current as at the version date of the document. We reserve the right to change product design, specifications or materials (Specifications) as part of our continuous improvement program. Please confirm the applicable Specifications at the time of placing your order.



LLIFE-SM-WP-CL

CLEVERTRONICS L10 LIFELIGHT IP65 WEATHERPROOF
SURFACE MOUNTED EMERGENCY LUMINAIRE WITH CORRIDOR LENS

SPACING TABLE

Manufacturer recommended spacing table and mounting heights for $\leq 2.5\text{m}$ corridor width, based on direct illuminance calculations (AS/NZS 2293.1); minimum light level of 0.2lx / 0.5lx avg

Mounting Height [m]	2.1	2.4	2.7	3.0	3.3	3.6	4.0	4.5	5.0	6.0	7.0
Fitting to Wall [m]	12.7	13.4	14.3	15.1	16.1	16.2	17.1	17.6	17.6	17.6	17.4
Fitting to Fitting [m]	33.0	35.5	37.8	40.0	42.0	43.9	46.0	48.5	50.5	50.3	35.8

Note: Spacing for mounting heights higher than 7.0m will depend on number of fittings used as the average of 0.5lx will change.
For specific requirements, different corridor widths and 1lx spacing tables please contact:
Clevertronics (info@clevertronics.com.au)

To determine actual spacings refer to section, 4.6.1.3 Illuminance calculations, of AS/NZS2293.1:2018.

ISOLUX LINE

